



MUNICIPAL CORPORATION
(Office of Dy. Health Officer: Rohini Zone)
Public Health Department
Sector-5, Rohini, Delhi-110085

Email: dhorohinizone15@gmail.com Tel: 011-27052106




No.-DHO/RZ/2026/170

Date : 02/6/26

SCHOOL HEALTH CERTIFICATE

It is certified that an inspection team headed by area Public health Inspector from Public Health department Rohini Zone inspected the **ST.FRENCIS CONVENT SCHOOL** situated at A-146, Jaswant Colony, Budh Vihar, Phase-II, Delhi-110086 and found that the **ST.FRENCIS CONVENT SCHOOL** has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus.

The above certificate is valid for the period of one year from date of issue.


Dy. Health Officer
Rohini Zone



Deputy Health Officer
Municipal Corporation of Delhi
Rohini Zone

Manager
ST.FRENCIS CONVENT SCHOOL
A-146, Jaswant Colony, Budh Vihar, Phase-II
Delhi-110086



DELHI JAL BOARD ;(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
WATER TREATMENT PLANT HAIDERPUR,
DELHI-110085



(ISO Certified 9001:2015)

**THE TEST REPORT IS
FOR THIS PARTICULAR
WATER SAMPLE ONLY**

Water samples collected from: - S1:- Before water cooler storage water, S2:- After water cooler student drinking point, in the premises of ST FRANCIS COVENT SCHOOL, A-146 JASWANT COLONY BUDH VIHAR PHASE-II, Delhi-86, vide challan no. 53, dated 13.05.2026.

S. No.	PARAMETERS	UNITS	B.I.S.10500:2012		S1	S2
			Desirable	Permissible		
1.	Date of Collection	--	---	---	-----15.05.2026-----	
2.	Date of Analysis	--	---	---	-----16.05.2026-----	
3.	Colour	C.U.	5	15	1.0	1.0
4.	Odour	--	Agreeable		Agreeable	Agreeable
5.	Turbidity	N.T.U.	1.0	5.0	0.70	0.62
6.	pH value	--	6.5 to 8.5	N.R.	7.79	7.80
7.	Electrical Conductivity	μmhos/cm	----	-----	314	313
8.	Total Dissolved Solid	(mg/l)	500	2000	204	203
*	CHEMICAL EXAMINATION					
9.	Phenolphthalein Alkalinity	(mg/l)	----	----	Nil	Nil
10.	Total Alkalinity	(mg/l)	200	600	82.0	81.0
11.	Total Hardness	(mg/l)	200	600	135.0	131.0
12.	Calcium Hardness	(mg/l)	----	----	90.0	89.0
13.	Magnesium Hardness	(mg/l)	---	----	45.0	42.0
14.	Calcium as Ca	(mg/l)	75	200	36	35.6
15.	Magnesium as mg	(mg/l)	30	100	10.8	10.1
16.	Ammonia (as NH ₃ -N)	(mg/l)	0.5	N.R.	ND	ND
17.	Nitrite –Nitrogen (N)	(mg/l)	---	---	ND	ND
18.	Nitrate NO ₃	(mg/l)	45	N.R.	2.72	2.73
19.	Sulphate (SO ₄)	(mg/l)	200	400	41.22	39.73
20.	Chloride (Cl)	(mg/l)	250	1000	11.5	12.5
21.	Iron (Fe)	(mg/l)	1.0	N.R.	ND	ND
22.	Fluorides (F)	(mg/l)	1.0	1.5	0.39	0.30
23.	Cyanides (CN)	(mg/l)	0.05	N.R.	ND	ND
24.	Residual Chlorine	(mg/l)	0.2	1.0	0.38	0.20
*	BACTERIOLOGICAL EXAMINATION					
25.	Coli form per 100 ml at 37 ⁰ c	MPN/100 mL	0		0	0

Remarks: On the basis of tested parameters, water samples 'S1' & 'S2' confirms to drinking water specification IS.10500:2012 and may be used for drinking purpose.

Asstt. Chemist

Chemist/Bacteriologist

A.C.W.A.